



MUNICIPAL CORPORATION CHANDIGARH

Public Health Laboratory at Water Works Sector - 39

TEST - REPORT

Not for legal use

Ref. No. & Date :- No.MED/2024-25/1807 dated: 25.02.2025
Issued to :- The Principal
:- Institute For the Blind
:- Sector - 26, Chandigarh
Quantity of sample :- Approximate 1200 ml .
Date of Collection :- 25-02-2025
Client reference :- Sample Collected by Laboratory Staff
Packing of sample :- Sample filled in P.P. and Glass Bottle
Source of sample :- from tap of Institute For the Blind
Sector - 26, Chandigarh


S.No.	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	-----	7.69
2	Odour	Agreeable	-----	Agreeable
3	Taste	Agreeable	-----	Agreeable
4	Turbidity	< 1.0	N.T.U.	0.8
5	Residual Chlorine	0.2 - 0.4	mg/l	0.2
6	Total Alkalinity (as CaCO ₃)	< 200	mg/l	92
7	Total Hardness (as CaCO ₃)	< 200	mg/l	78
8	Chloride (as Cl)	< 250	mg/l	04
9	Free & Saline Ammonia	NIL	mg/l	NIL
10	Total Dissolved Solids	< 500	mg/l	132
11	M.P.N. of Coliform Bacilli Per 100ml of water	Zero	M.P.N.	0 (Excellent)

Note: Water is fit for drinking.

Lab No.- MCPHL/25/6.58.....

Dated:- 01.03.2025


Chemist
M.C.P.H. Laboratory
Chandigarh



Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh
Dated :-01.03.2025

Endst No. MCPH/25/.....

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector-17, Chandigarh
For Information Please.


Chemist
M.C.P.H. Laboratory
Chandigarh


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1
Chandigarh


Principal
Institute for the Blind
Sector-26, Chandigarh



MUNICIPAL CORPORATION CHANDIGARH
(Medical Officer of Health)

(SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE)
(NO OBJECTION CERTIFICATE)

No. MOH/Supdt.Admn/NOC/2025/ 4076

Dated:- 18/3/25

It is certified that an inspection team headed by Sh.Darshan Singh, Chief Sanitary Inspector from Office of Medical Officer of Health, Municipal Corporation Chandigarh inspected the Institute for the blind, Sector 26, Chandigarh on 25-02-2025 and mentioned in inspection report that of the Institute for the blind, Sector 26, Chandigarh is maintaining the hygienic sanitation condition in the premises as per the norms prescribed by the Central/State/U.T Govt. India.

The above Certificate is valid for a period of One-year w.e.f
25.02.2025 (i.e. Inspection Date).


Medical Officer of Health
Municipal Corporation
Chandigarh

✓ To
Institute for the blind,
Sector 26,
Chandigarh


Principal
Institute for the Blind
Sector-26, Chandigarh